CIVIL TECH LABS

TEST ON WMM MIX

Name of the Client	AEE, Kodigehalli Sub Division, BBMP
Project	Improvements and Asphalting to Roads and Drains at Defence Enclave Mariyanna Palya in Ward No. 07, Kodigehalli Sub Division.
Agency	Sri. Chandra Naik R.
Date of Testing	20/04/2013
Reference	**MORTH Table 400-11**

IS Sieve Designation (mm)	% By Weight Passing IS Sieve	Actual % By Weight Passing IS Sieve	Remarks
53	100	100	**Satisfies Requirements**
45	95-100	98.5	
22.4	60-80	76.6	
11.2	40-60	53.6	
4.75	25-40	34.7	
2.36	15-30	24.3	
0.6	8-22	18.1	
0.075	0-8	5.9	

Note:

1.The results relate only to the items tested.

2.Report shall not be reproduced except in full, without the written approval of the lab.

3.Any correction invalidates this report.

4.The results are based on the test conducted on samples supplied by the client.

CIVIL TECH LABS
5, I Floor, ICross
Srinivasa Colony, Mission Road
BANGALORE-560 027

CIVIL TECH LABS BANGALORE

Lab Incharge
Civil Tech Labs